



Bharat Heavy Electricals Limited
Electroporcelains Division, Bangalore – 560 012

Control Panel Business Group

ANNEXURE-A

Technical specification for Protective Insulation mat for LT control panels

- 1. Item to be supplied as per IS standard ref no: 15625.2006**
 - (i) Class –A , AC RMS -3.3 KV , DC – 240V**
 - (ii) Minimum thickness-2mm, Minimum width -1000mm , length – as per requirement**
 - (iii) Bidder shall have BIS license to manufacture & supply Insulation mats. A valid license shall be submitted at the time of tender and in the event of order Bidder shall ensure that license shall be valid throughout the rate contract.**



Bharat Heavy Electricals Limited
Electroporcelains Division, Bangalore – 560 012

Control Panel Business Group

PRE – QUALIFICATION REQUIREMENT

1. Bidder shall have BIS license to manufacture & supply insulation mats .A valid license shall be submitted at the time of tender and in the event of Bidder shall ensure that license shall be valid throughout the rate contract.
2. Minimum Capacity of the vendor per month shall be 3000mts